

BLOCK WATER TESTING LABORATORY, TALWARA

Division Talwara, Hajipur-Sathwan road, Pin Code - 144222
BLWTLtai@gmail.com

To,

Principal Harvard International School
Vill. Bhatoli, P.O Mand Pandher


No.: BWLTAL/2425/00253 Dated : 26/03/2025


Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. HIS/B/03/677 Dated: 18/03/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/03/2025. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Talwara

D/A : Test Report •


Principal
Harvard International School
Vill. Bhatoli, P.O. Mand Pandher
Teh. Dasuya, Distt. Hoshiarpur (Pb.)


Authorized Signatory
For, Block Water Testing Laboratory
Talwara


President
MANAGING COMMITTEE
Harvard International School
Vill. Bhatoli, P.O. Mand Pandher
Teh. Dasuya, Distt. Hoshiarpur (Pb.)

BLOCK WATER TESTING LABORATORY, TALWARA

Division Talwara, Hajipur-Sathwan road, Pin Code - 144222

BLWTLtal@gmail.com


TEST REPORT

Name & Address of Customer : Principal Harvard International School Vill. Bhatoli, P.O Mand Pandher		Customer Reference No.	No : HIS/B/03/677 Dated : 18/03/2025
		Sample Submitted by	Principal
		Date of Sample Receipt	18/03/2025
		Analysis Starting Date	21/03/2025
		Analysis completion Date	22/03/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	NABLDWT00254 2549F	Sample Type :	Water
Test Report No.:	BWTLTAL/2425/00253	Date of Issue :	26/03/2025
Registration no.:	BWTLTAL/REG2425/00775	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Harvard International School, Vill. Bhatoli / 120 ft
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Dasuya	District :	Hoshiarpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.60	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	283	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.53	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	199.92	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	205.64	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	62.20	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	12.26	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	26.36	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :


1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%


Principal
Harvard International School
Vill. Bhatoli, P.O. Mand Pandher
Teh. Dasuya, Distt. Hoshiarpur (Pb.)

Reviewed and Approved By


Mr. Ankur Joshi
Chemist/Analyst
Authorized Signatory
For, Block Water Testing Laboratory
Talwara

End of the Test Report


President
MANAGING COMMITTEE
Harvard International School
Vill. Bhatoli, P.O. Mand Pandher
Teh. Dasuya, Distt. Hoshiarpur (Pb.)